



DO'S AND DONT'S



| | ✓ Do's | Dont's |
|---|---|---|
| | Upon receipt of shipment unload and store the batteries in covered area. | Do not keep the batteries in places |
| | Read 'Installation and operating "Instruction Manual" prior to installation of the batteries. | Do not boost charge the batteries for more than 24 hrs. In regular operation / usage. |
| ja se | Clean the batteries as and when dust accumulates. | Do not attempt to dismantle the battery. |
| | Provide sufficient ventilation, if the batteries are placed in cubicle. | Do not over tighten the terminal bolts. |
| A States of the | The terminal bolt connection to be torque as specified in O&M manual. | Do not allow any metal objects to rest on the battery or fall across the battery terminals. |
| Ę Ţ | Re-torque the connections once in every six months. | Do not mix the batteries of different capacities or makes. |
| 8 | Keep the batteries away from heat source, sparks, fire etc | Do not add water or acid. |
| (4) | Charge the batteries once in every six months, if stored for long periods. | Do not mix ordinary conventional / low maintenance batteries with AMARON QUANTA [™] SMF Batteries. |
| Ēð | After a discharge, recharge the batteries immediately. | |
| | Note down module voltage readings once in every month. | |